

Aquatic Venue Log Sheet

Month/year:	
Pool name:	
Pool manager/operator:	
Pool Hours of Operation:	
Type of disinfectant (see below):	

			Prior to opening & Every 4 hrs			Test Daily (Prior to Opening)				Test Weekly	*	Chemicals Added/Actions Taken	
Day	Time	Initials	pH	ORP mV/pH	FAC/Bromine	Total Chlorine	CAC *	Temp.	Flow Rate	Alkalinity	Cyanuric	Disinfectant/Chemicals and Amount Added	Comments (closure, injury, clarity, etc.)

*Combine Chlorine = Total Chlorine – Free Chlorine
 * Cyanuric acid tested every 2 weeks for venues that use stabilize chlorine. Monthly for venues that manually add cyanuric acid (outdoor use only)

What Your Readings Mean:

- **GREEN** readings meet the requirements; no additional action needed
- **RED** readings mean your pool **DOES NOT MEET REQUIREMENTS**. Take immediate action, retest, then reopen your pool when readings are **GREEN**.
- **Pools that are found open and operating with RED readings will be closed and/or reinspected by NMED.**

Water Quality Reading		GREEN	RED
pH		7.2 – 7.8	Less than 7.2 OR More than 7.8
Disinfectant	Chlorine	1.0 – 10.0 ppm Spa (3-10ppm)	Less than 1.0 ppm (3ppm for spa) OR Greater than 10.0 ppm
	Stabilized Chlorine • (Utilizing Cyanuric Acid)	2.0 – 10.0 ppm Spa (3-10ppm)	Less than 2.0 ppm (3ppm for spa) OR Greater than 10.0 ppm
	Bromine	3.0 – 8.0 ppm for Pools (4.0 – 8.0 for Spas)	Less than 3 ppm (4ppm for spas) OR Greater than 8ppm
Temperature		Maximum of 104 ^o F	Greater than 104 ^o F
Cyanuric Acid (outdoor use only)		Maximum of 100 ppm	Greater than 100 ppm
Clarity		Clear	Hazy, cloudy, main drain or bottom not visible
Main drains		Main drain covers secured in good condition	Main drain covers cracked, missing, loose
Filtration System/Automatic Controllers		Operating properly	Not operating, operating poorly

